

# ATTESTATION OF CONFORMITY

No. 207810500

Issued to: Lightspeed Systems B.V.  
Zompstraat 12  
8102 HX Raalte  
The Netherlands

For the product: Optical Detection System  
Model/type: OSP.07.03

Ratings: Input: 12-24 Vdc, nominal 80 mA, max. 110 mA

Manufactured by: Lightspeed Systems B.V.  
Zompstraat 12  
8102 HX Raalte  
The Netherlands


Trademark: Lightspeed

Requirements: EN 954-1 (1996); ISO 13849-1 (1999)  
Fail-safe controls, Category 4 classification

This Attestation is granted on account of an assessment and tests made in our laboratory, the results of which are laid down in our report no. 2078105.01-QUA/PEP

The examinations have been carried out on one single specimen of each product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

KEMA Quality B.V.  
Arnhem, October 18, 2006



A.G.H. Bergervoet

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

**KEMA Quality B.V.**

Utrechtseweg 310, 6812 AR Arnhem. P.O. Box 5158, 6802 ED Arnhem, The Netherlands.  
Telephone +31 26 3 56 20 00, Telefax +31 26 3 52 58 00.